

CERTIFICATE OF COMPLIANCE

Certificate Number 20191028-E510744
Report Reference E510744-20191025
Issue Date 2019-OCTOBER-28

Issued to: Zarlec
115 8th Street
Sealy TX 77474

This certificate confirms that representative samples of

Industrial Control Panels Relating To Hazardous Locations
Provided with intrinsically safe circuit extensions for use in Class I, Division 1, Groups A, B, C and D; Class II, Division 1, Groups E, F, G; and Class III Hazardous Locations, when connected in accordance with the appropriate installation instructions.

Have been investigated by UL in accordance with the Standard(s) indicated on this Certificate.

Standard(s) for Safety: UL 698A, Industrial Control Panels Relating to Hazardous (Classified) Locations


CAN/CSA C22.2 No. 157-92, Intrinsically Safe and Non-incendive Equipment for Use in Hazardous Locations

See the UL Online Certifications Directory at <https://iq.ulprospector.com> for additional information.

This *Certificate of Compliance* does not provide authorization to apply the UL Mark. Only the UL Follow-Up Services Procedure provides authorization to apply the UL Mark.

Only those products bearing the UL Mark should be considered as being UL Certified and covered under UL's Follow-Up Services.

Look for the UL Certification Mark on the product.



Bruce Mahrenholz, Director North American Certification Program

UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact a local UL Customer Service Representative at <http://ul.com/aboutul/locations/>

