

CERTIFICATE OF COMPLIANCE

Certificate Number 20191029-E510745
Report Reference E510745-20191028
Issue Date 2019-OCTOBER-29

Issued to: Zarlec
115 8th Street
Sealy TX 77474

**This certificate confirms that
representative samples of**

**INDUSTRIAL CONTROL PANELS AND ASSEMBLIES
FOR USE IN HAZARDOUS LOCATIONS**
See Addendum Page for Models

Have been investigated by UL in accordance with the
Standard(s) indicated on this Certificate.

Standard(s) for Safety:

See Addendum Page for Standards

Additional Information:

See the UL Online Certifications Directory at

<https://iq.ulprospector.com> for additional information.

This *Certificate of Compliance* does not provide authorization to apply the UL Mark. Only the UL Follow-Up Services Procedure provides authorization to apply the UL Mark.

Only those products bearing the UL Mark should be considered as being UL Certified and covered under UL's Follow-Up Services.

Look for the UL Certification Mark on the product.



Bruce Mahrenholz, Director North American Certification Program

UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact a local UL Customer Service Representative at <http://ul.com/aboutul/locations/>



CERTIFICATE OF COMPLIANCE

Certificate Number 20191029-E510745
Report Reference E510745-20191028
Issue Date 2019-OCTOBER-29

This is to certify that representative samples of the product as specified on this certificate were tested according to the current UL requirements.

Industrial Control Panels, Explosion-Proof, for Use in Class I, Division 1, Groups B, C and D Hazardous Locations.

May be provided with intrinsically safe circuit extensions for use in Class I, Division 1, Groups A, B, C and D; Class II, Division 1, Groups E, F and G; and Class III Hazardous Locations.


Standard(s) for Safety:

UL 1203, EXPLOSION-PROOF AND DUST-IGNITION-PROOF ELECTRICAL EQUIPMENT FOR USE IN HAZARDOUS (CLASSIFIED) LOCATIONS

CSA C22.2 NO. 30-M1986, EXPLOSION-PROOF ENCLOSURES FOR USE IN CLASS I HAZARDOUS LOCATIONS

UL 698A, INDUSTRIAL CONTROL PANELS RELATING TO HAZARDOUS (CLASSIFIED) LOCATIONS

CSA C22.2 NO. 157-92, INTRINSICALLY SAFE AND NON-INCENDIVE EQUIPMENT FOR USE IN HAZARDOUS LOCATIONS



Bruce Mahrenholz, Director North American Certification Program

UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact a local UL Customer Service Representative at <http://ul.com/aboutul/locations/>

